

2013 ASHRAE Competition

HVAC Design Calculations

The Team:

Jayson Bursill

Senior Mechanical Engineering Student
University of British Columbia Graduate,
May 2013

Present and Permanent Information:

3040 Southern Place
Abbotsford, B.C. V2T 5H6
jayson.bursill@gmail.com / 604-556-6973

Natasha Palmer

Senior Mechanical Engineering Student
University of British Columbia Graduate,
May 2014

Present and Permanent Information:

2765 West 33rd Ave
Vancouver, B.C. V6N 2E9
natasha.b.palmer@gmail.com / 604-338-5032

Angela Walton

Senior Mechanical Engineering Student
University of British Columbia Graduate,
May 2013

Present and Permanent Information:

#112-175 West 1st. Street
North Vancouver, B.C. V7M 3N9
walton.angelac@gmail.com / 604-363-3734

Gavin Wong

Senior Mechanical Engineering Student
University of British Columbia Graduate,
May 2013

Present and Permanent Information:

#23-5988 Lancing Road
Richmond, B.C. V7C 3A8
gavinwong_@hotmail.com / 778-988-5233

Sponsoring Chapter

British Columbia Chapter

School

University of British Columbia
Department of Mechanical Engineering

111-3790 Canada Way
Burnaby, B.C. V5G 4S2

2054-6250 Applied Science Lane
Vancouver, B.C. V6T 1Z4



University of
British Columbia
Student Branch



Advisory Panel:

Faculty Advisor:**Dr. Nima Atabaki**

Mechanical Engineering Instructor
University of British Columbia

Present and Permanent Information:

2054-6250 Applied Science Lane
Vancouver, B.C. V6T 1Z4
natabaki@mech.ubc.ca / 604-827-4065

Faculty Advisor:**Dr. Steven Rogak**

Mechanical Engineering Professor
University of British Columbia

Present and Permanent Information:

2054-6250 Applied Science Lane
Vancouver, B.C. V6T 1Z4
rogak@mech.ubc.ca / 604-822-4149

Industry Advisor:**Geoff McDonell**

Associate Principal
Integral Group

Present and Permanent Information:

Suite 180-200 Granville St
Vancouver, B.C. V6C 1S4
gmcdonell@integral-group.ca / 604-687-1800

Table of Contents

Executive Summary	1
Location and Environmental Conditions	2
Design Criteria	2
System Sizing.....	3
Heating and Cooling Load Calculations	3
Zoning	3
Modeling	3
Alternative Energy Conservation Measures.....	7
Illustrated Cooling and Heating Sample Calculations	8
Summary of Ventilation and Duct Sizing Calculations	8
Summary of Pipe Sizing Calculations.....	8
Design and Analysis	9
System Selection.....	9
Equipment Selection	10
Energy Analysis	11
Economic Analysis	12
ASHRAE Standard Compliance	13
ASHRAE 55.....	13
ASHRAE 62.1.....	15
ASHRAE 90.1.....	15
Conclusion	15
Acknowledgments.....	16
References.....	16



Executive Summary

The contents of this report provide a summary of the process that we used to design the HVAC system for the Dallas Power and Light building using Ottawa, Ontario's weather conditions. Ottawa's climate conditions were used because it facilitates the design of an HVAC system with significant heating and cooling, rather than primarily cooling in the climate of Dallas, Texas. The main factors in the design were Location and Environmental Conditions, Design Criteria, System Sizing, and ASHRAE Standard Compliance. The Location and Environmental Conditions and Design Criteria sections of the report outline the framework that we used for our design given our choice of climate and the competition requirements from both the judging criteria and Owner's Project Requirements (OPR). The System Sizing section provides insight into the heating and cooling load calculations, our sample hand calculations used to verify the validity of the software, and the piping and ducting transit calculations. The Design and Analysis section details our final plant system type selection, major equipment selection, energy analysis of the building, and economic analysis of equipment choices. The ASHRAE Standard Compliance section elaborates on how we met ASHRAE 55-2010, ASHRAE 62.1-2010, and ASHRAE 90.1-2010. Mechanical drawings have also been provided to illustrate the final design.

Trane's software package with TRACE 700, Trane Pipe Designer, and VariTrane Duct Designer was used. TRACE 700 was used to determine the heating, cooling, and ventilation loads. The pipe and duct design software (verified with hand calculations) was used to determine the losses from transit for sizing and pressure loss calculations. AutoCAD was used to generate mechanical drawings detailing all of the HVAC related mechanical equipment within the building.

ASHRAE 90.1-2010 Zone 6A R-values were assumed for all constructions because there was not enough information given in the OPR to simulate the construction on a layer by layer basis, and a baseline model using the prescribed minimum efficiencies was used to determine the efficiency of the design. ASHRAE 62.1-2010 ventilation calculations were applied to the software to ensure minimum flow rates were maintained, and diffuser and grille placements were done with care to avoid discomfort and air contamination. ASHRAE 55-2010 compliance was demonstrated using an operative temperature calculation for the southern zone of the retail space that is heated with radiant panels.

Preliminary modelling using eQuest suggested that ground-source heat pumps would provide significant energy savings over a traditional boiler and chiller system, but further analysis demonstrated that the payback would be over 15 years for a vertical well system. Additionally, a horizontal well system would not be practical given the building's lack of underground parking and location in a downtown core. This led to the choice of a boiler and chiller based hydronic plant. The biggest design challenge for this building was the limited mechanical space available for large plant equipment and exhaust ducting. As a result, an air-cooled chiller was selected to be placed on the roof, and high efficiency, small footprint boilers were to be placed in Maintenance 113. Air-cooled chillers typically have lower Energy Efficiency Ratings (EERs) than the water-cooled variety, but in the case of the Dallas Power and Light building, there was little space for a cooling tower.

The results of our load calculations yielded building cooling and heating loads of 26 Btu/hr-ft² and 28 Btu/hr-ft² respectively. We applied these values when selecting the final design. The final design for the building was an air-cooled heat recovery chiller for cooling, and high efficiency condensing boilers for heating. Heat recovery was implemented via heat pipes to allow for washroom exhaust recovery. Hydronic radiant panels were used for skin heating in the first floor retail space to lower the room air temperature and maintain occupant comfort. When compared to the ASHRAE 90.1-2010 baseline our design was 8% more efficient. This is a considerable amount of savings given the constraints we had on mechanical space and terminal unit selection for the Ottawa climate.

Location and Environmental Conditions

This year's competition gave us the option of relocating the Dallas Power and Light building to the capital city of our country for weather conditions, which allowed us to relocate to the climate of Ottawa, Ontario Canada. Ottawa is situated in Zone 6A (as per ASHRAE 90.1-2010) and sees both humid summers and sub-arctic winters. This comparatively adverse climate offered our design team a chance to showcase a greater knowledge of HVAC equipment than if the building were located in cooling dominated Dallas, Texas. 2% Design criteria was used for the summer (as per the Owner's Project Requirements), and 99% criteria for the winter as outlined in Table 1. The choice of using 99% criteria for winter was to provide an additional safety factor for the cold winter that can reach -6°F. For the purposes of software and hand calculations, Typical Meteorological Year (TMY) data from Ottawa International Airport was used.

Table 1: Design Temperatures for Ottawa, Ontario

Season	Degree Days	Design Temperatures
Winter	8571 HDD	-6°F @99%
Summer	2045 CDD	81°F DB @2% 67°F WB @2%




Figure 1: Canadian Climate Zones

Design Criteria

The Judging criteria outlines how the final design will be evaluated, but the Owner's Project Requirements (OPR) gives the framework for how the design should be implemented. In order to win the competition both sets of requirements must be satisfied. The Owner's Project Requirements are as follows:

- HVAC equipment must have low impact on energy and water consumption.
- Strict acoustic criteria must be met (less than NC 30 for the suites and NC 40 for the retail space).
- Ventilation must provide excellent air quality.
- Mechanical equipment must be "near invisible", but accessible for good maintenance.
- Each apartment must have individual comfort control.
- Ceiling height must be maximized.
- Mechanical space must be minimized.
- Retail space HVAC equipment must have a flexible design to account for changes in use and occupancy.

The judging criteria is shown in Table 2. As implied by the rubric, half of the total points are allocated to sound technical design (System Sizing, ASHRAE Standards), and the other half is allocated to creativity and presentation. The sections that follow will describe how our design fulfills these objectives.

Table 2: ASHRAE HVAC Design Calculations Competition Judging Criteria

Category	Maximum Points
System Sizing	300
ASHRAE Standards	200
Creativity	200
Communication of Results	300
TOTAL	1000

System Sizing

Heating and Cooling Load Calculations

Correct modeling of the building's heating and cooling loads is critical to producing a good design. Proper equipment sizing is important in keeping capital costs as low as possible while ensuring the majority of the building's occupants are comfortable.

Trane's TRACE 700 software and its accompanying pipe and duct designer software was selected to execute the heating and cooling equipment, pipe, and duct sizing for the Dallas Power and Light Building. Understanding the methodology behind the software's calculations is essential to good design. As such, TRACE 700's calculated loads were cross-checked with hand calculations as outlined in the Illustrated Cooling and Heating Sample Calculations section.

Terminal equipment was sized using peak loads, while the plant equipment was sized to meet the maximum block load of the building and to account for load diversity and setback conditions. This accounts for the fact that different faces of the building will see their respective peak loads at different hours of the day. The ratio of the block load to the peak load gives a diversity factor that can be applied to other portions of the HVAC system (pumping, fans, etc.).

Zoning

The figures below show the zone division of characteristic floors of the building. The first floor Variable Air Volume (VAV) system is divided based primarily on tenant and exterior wall orientation, while the other floors that contain suites are divided based on suite (with some bedrooms solely occupying a control zone to provide better granularity in cases where the exterior wall orientations of the main suite and bedroom are not concurrent).




Figure 2: Retail Zoning Diagram



Figure 3: Residential Zoning Diagram

Zoning on the multi-floor suites (Level 17/18 and 19/20) was broken down into one zone per floor, unless high glazing loads required further zone breakdown (i.e. Suite 1903).


Modeling

The first step to creating a good energy model is to verify the information that has been given by the project stakeholders, assemble the local climate conditions, and to state and validate design goals. Table 3 illustrates those values and assumptions.

Design Model Characteristics	
General	
Location	Ottawa, Ontario
Simulation Weather File	Ottawa, Ontario
Climate Zone	ASHRAE Climate Zone 6
Modeling Software	TRACE 700
Hours of Operation	Residential: 24 hours (with reduced occupancy in working hours) Retail: 8am-9pm
Utility Rates	<div>Electrical:</div> <div>On-peak Consumption - \$0.085/kWh</div> <div>Off-peak Consumption - \$0.045/kWh</div> <div>On-peak Demand - \$5.75/kW</div> <div>Gas:</div> <div>Consumption - \$0.75/Therm</div>
Floor Area	108,000 ft ²
Envelope Performance	
Overall Roof U-value (Btu/hr·°K·ft ²)	U-0.048 (R-20)
Overall Wall U-value (Btu/hr·°K·ft ²)	U-0.071 (R-15.2)
Percentage Glazing	Overall: 27%
Overall Glass U-value including frame (Btu/hr·°K·ft ²), and Solar Heat Gain Coefficient (SHGC)	<div>U-0.478</div> <div>SHGC_{all}-0.4</div> <div>Double low-e air filled</div>
Internal Loads	
Occupancy Density	<div>Bedroom/Living: 100 ft²/person</div> <div>Kitchen: 50 ft²/person</div> <div>Lobby: 33 ft²/person</div> <div>Mechanical: 200 ft²/person</div> <div>Office: 200 ft²/person</div> <div>Retail: 67 ft²/person</div> <div>Storage: 500 ft²/person</div> <div>Restrooms: 1 person/fixture</div>
Lighting Power Density (LPD)	<div>Bedroom/Living: 1.11 W/ft²</div> <div>Corridor: 0.66 W/ft²</div> <div>Kitchen: 0.99 W/ft²</div> <div>Lobby: 0.90 W/ft²</div> <div>Mechanical: 0.95 W/ft²</div> <div>Office: 1.11 W/ft²</div> <div>Restrooms: 0.98 W/ft²</div> <div>Retail: 1.68 W/ft²</div> <div>Storage: 0.63 W/ft²</div>
Plug-Loads (EPD)	Office: 0.50 W/ft ²
Domestic Hot Water Usage	2100 Btu/h.Person
Mechanical Systems	
Indoor Design Temperature	Occupied: 70°F/75°F Unoccupied: 64°F/81°F
Humidity Control	<div>Humidification: Electric</div> <div>High-limit: 60%</div> <div>Low-limit: 30%</div>
System Description	<div>Residential: Rooftop Dedicated Outdoor Air System (DOAS) with fan coil terminal</div> <div>Retail: Air Handling Unit (AHU) with reheat</div>
Fan Power & Control	<div>Fans run continuously during occupied hours and cycle on/off to meet the heating/cooling loads during unoccupied hours.</div> <div>Design air flows are based on a supply-air-to-room-air temperature difference of 20°F</div> <div> <div>AHU-1 (Suites)</div> <div>Fan total static pressure:</div> <div>Supply: 1.88 in.wg</div> <div>HR Return: 1.97 in.wg</div> </div> <div> <div>AHU-2 (1st Floor Retail)</div> <div>Fan total static pressure:</div> <div>Supply: 1.98 in.wg</div> <div>HR Return: 1.54 in.wg</div> </div>

Design Model Characteristics	
	<div> <div> Fan total power: Supply: 7.5 HP HR Return: 7.5 HP Fan total air flow: Supply: 12650 cfm HR Return: 9500 cfm </div> <div> Fan total power: Supply: 5 HP HR Return: 5 HP Fan total air flow: Supply: 6100 cfm (+1700 cfm relief) HR Return: 7800 cfm </div> </div>
Ventilation Controls	Zone level thermostat
Heat Recovery	Air-to air heat recovery with 56.2% sensible effectiveness.
Central Plant	
Heating Type	Natural gas condensing boilers with 91% efficiency
Hot Water Loop	Temperature: Design supply: 160°F Design loop DT: 20°F Hot water supply temperature is reset based on load.
Cooling Type	Air cooled heat recovery chiller: 9.93 EER
Chilled Water Loop	Temperature: Design supply: 44°F Design loop DT: 10°F Chilled water supply temperature is reset based on outdoor air temperature.
Domestic Water Heater	Gas-fired domestic water heater with 96% efficiency
Pumps	Primary/Secondary pumps are modeled with Premium-efficiency motors and Variable-Speed drives.

In addition to meeting all of the relevant ASHRAE standards (55-2010, 62.1-2010, and 90.1-2010), physical features of the building must be considered. The combination of punched windows and thick mass wall has left the majority of the building's windows with some usable shading represented as "overhangs" and "fins". The model accounts for the shading that is generated by these features on a face-by-face and floor-by-floor basis to provide the most accurate estimation of



- Depth of punched window recession from envelope edge is measured (b), along with window width (a).
- Measurement is repeated in the vertical plane.
- Shading scheme is used to generate shading coefficients that reduce direct solar loads.

load reduction. An illustration of the effective portions of the overhangs can be seen in Figure 4.

The heavy construction of the Dallas Power and Light building that was common in the 1930's also provides a "thermal mass effect" that delays and reduces the peak cooling load from the peak envelope load. This effect allows the building to store radiant heat that is projected into the building at peak solar angle times (noon for South faces, morning for East faces, evening for West faces, and sunrise/sunset for North faces), and use convection to release it later. The walls of the building act as "thermal masses" and store energy. As a result, the peak load for the HVAC system can be lower than the peak load of the space. The time-variant properties for various materials are documented in the ASHRAE Fundamentals handbook, and are the basis for Radiant Time Series (RTS) cooling load calculations used in the TRACE 700 software. We used the RTS method for this project because of its accuracy and popularity in industry.

Figure 4: Typical 1st Floor Punched Window Indentation (Plan View)

The walls of the building act as "thermal masses" and store energy. As a result, the peak load for the HVAC system can be lower than the peak load of the space. The time-variant properties for various materials are documented in the ASHRAE Fundamentals handbook, and are the basis for Radiant Time Series (RTS) cooling load calculations used in the TRACE 700 software. We used the RTS method for this project because of its accuracy and popularity in industry.

In addition to standard infiltration caused by wind and pressure differences between both sides of the envelope, tall and relatively narrow buildings such as the Dallas Power and Light building tend to exhibit symptoms of the stack effect. The stack effect is a phenomenon where excessive infiltration combining with warm air rising causes the shafts of the building to draw air upward and generate a negative pressure in the lower portion of the building, and higher pressure at the top. It

can be particularly prevalent in cold climates such as Ottawa. We used the stack effect calculation from ASHRAE Fundamentals 1997 to find the flow rate at design conditions. The equation we used is as follows:

$$Q = 60 \times C_d \times A \times \sqrt{2 \times g \times (H_n - H_b) \times (T_i - T_o/T_i)}$$

With the following variables:

Table 4: Stack Effect Inputs

Variable	Q	C _d	A	T _i	T _o	H _n	H _b	g
Meaning	Stack flow rate	Drag coefficient	Opening area (air gap)	Indoor temp	Outdoor temp	Height of "neutral plane"	Height of base opening	Gravity
Assumed Value	2450 CFM	0.65	2 ft ²	68°F	-6°F	110 ft	0 ft	32.2 ft/s ²

As Observed in Table 4, we found the stack effect flow rate to be just below 2500 CFM at heating design conditions. When compared with the general infiltration flow rate of 14,500 CFM obtained from the TRACE 700 model (also at heating design conditions), the stack effect can be neglected. Additionally, fan coils with corridor service were slightly oversized for ventilation to pressurize the corridors in an effort to reduce infiltration.

The monthly heating and cooling equipment loads follow the energy usage profile shown in Figure 5. The building's end use breakdown of energy consumption is shown in Figure 6. Note the high heating load in both figures. This was considered in the choice of high efficiency condensing boilers.





Figure 5: Monthly Breakdown of Heating and Cooling Equipment Energy Consumption

Energy Breakdown by End Use



Due to the cold/dry winter climate and hot/humid summer climate of Ottawa, Ontario, it was found that there was both a significant heating and cooling season. The heating season's intensity initially brought the relative humidity of the supply air down to 20%, but the addition of domestic hot water line supplied humidifiers to the air handling units brought the Relative Humidity (RH) back to a reasonable level (30-60%).

The building's block loads and engineering checks from TRACE 700 are summarized in Table 5 and Table 6 respectively. Note that a safety factor of 10% was used on heating equipment, and the 2 boilers were sized so that each could provide 55% of the building load to prevent equipment damage in the case of a malfunction. The cooling equipment was not oversized because cooling is a less critical function in Ottawa.

Figure 6: Breakdown End Use Energy Consumption

Alternative Energy Conservation Measures

Two alternative Energy Conservation Measure (ECM) models were run to demonstrate opportunities where significant lifetime savings could be obtained based on Dallas Power and Light management decisions. These alternatives included consideration of shading from the 37-storey Whitacre Tower located less than 50 feet West of the Dallas Power and Light tower, as well as the selection of triple-paned windows in response to the cold winters of Ottawa.

Shading from the Whitacre Tower could provide considerable reduction in cooling loads for the West exterior wall. This would affect roughly one third of the building's suites, and could reduce the capital cost of the HVAC system. The drawback would be that if the Whitacre Tower was unforeseeably removed, the equipment would no longer be adequate for the building's loads. If accounted for, the shading from the Whitacre Tower could have reduced our cooling equipment size by 8%.

Triple-paned windows are seeing frequent use in arctic and sub-arctic climates such as the Yukon Territory and Ontario. The energy savings from adding an additional inert space between the environment and the conditioned space are undeniable, but higher capital costs could give this ECM a negative Net Present Value (NPV). We found that the use of moderately tinted Triple-paned windows would reduce our heating and cooling equipment size by 14% and 25% respectively.

Table 5: Building Block Loads

End Use	Block Load
Heating	3,100 MBh
Cooling	200 Tons
Ventilation (Total Supply)	110,000 CFM
Ventilation (Outdoor Air)	16,200 CFM

Table 6: Engineering Checks for a West Facing Suite (Suite 1001)

Check	Value
CFM/ft ² (Cooling)	0.91
Btu/hr-ft ² (Cooling)	26.32
CFM/ft ² (Heating)	0.91
Btu/hr-ft ² (Heating)	28.05

Illustrated Cooling and Heating Sample Calculations

Accurately evaluating heating and cooling loads is imperative as it governs whether equipment is sized adequately. As such, the Trace 700 software used to assess heating and cooling loads must be validated. The east-facing bedroom of suite 306 was chosen for a simple analysis for which calculations were performed.

Before cooling loads are calculated, the sol-air temperature must be determined for the hottest month using Ottawa's design conditions at 2% criteria. The Radiant Time Series (RTS) and Conductive Time Series (CTS) methods were applied to find the heating and cooling loads in both the model and the hand calculations. In the comprehensive analysis, infiltration, lighting, and occupant heat gains were also considered for cooling loads. Alternately for heating, solar and internal heat gains are neglected as building structures and contents are considered to have zero thermal inertia. The following table outlines the heating and cooling loads from manual calculation, Trace 700, and the difference.

As observed in the calculations, the differences are relatively small, and any deviation is likely caused by small rounding errors propagating throughout the computation. For a summary of the block loads please refer to Table 5 in Modeling.

Table 7: Comparison of TRACE 700 Loads and Hand Calculated Loads

Cooling Load	Trace 700	Manual Calculation	Difference (%)
Wall (Btu/hr)	190	198	4.1
Window (Btu/hr)	2077	2273	8.6
Heating Load			
Wall (Btu/hr)	501	495	1.1
Window (Btu/hr)	1008	1126	10.5

Summary of Ventilation and Duct Sizing Calculations

The ducting layouts were drawn keeping in mind the requirements of maximized ceiling height, almost invisible mechanical equipment, and low noise criterion. For the most part, the ducting was run through areas where a dropped ceiling would be acceptable, in the kitchens, bathrooms, closets and entry corridors. The maximum ceiling height for the residential space is 12 ft. In the areas where the ceiling was dropped, it reaches a height of 8 ft.

The duct sizing was done with the VariTRANE Duct Designer software, which allows the user to dictate the maximum section velocity, section elevation, inline fittings, duct roughness and many other important parameters. The resulting duct sizes were randomly checked using a hand calculator where the required air quantity was set with the desired velocity. When the duct sizes were compared using both the software and hand calculator they often differed by only half a size.

Summary of Pipe Sizing Calculations

The hydronic system is designed to minimize the number of branches into individual suites. As such, the main pipes run along the corridor and branch off into suites as smaller networks when necessary. Pipe sizing was performed using Trane Pipe Designer. The software optimizes the required size based on flow rates, frictional losses, and material cost. Additionally, it provides the critical path of the network with information on pressure drop and flow rates. A simple closed-loop system was implemented to verify the validity of the software. The Darcy-Weisbach equation and the methods outlined in Chapter 22 of ASHRAE Fundamentals 2009 were used to derive the head loss and pipe diameter.

Overall, the results had a difference of approximately 10%. This mostly originates from the assumptions made (e.g. fitting losses, steel pipe surface roughness). However, the findings did indeed show expected behavior when pipe diameter was changed, and prove that the software utilizes similar theories in determining pressure losses. To reduce pressure drop, pipes have been upsized to the next largest size wherever reasonable. Doing so will help reduce flow velocity and noise, and ultimately the lifetime energy consumption. This method of pipe upsizing is common practice in Europe where energy costs hold more weight in equipment sizing.

The head loss and flow rate were used as the primary factors in pump sizing. Due to the boiler rooms location on the ground floor, the additional hydrostatic pressure from the riser column needs to be accounted for. This approximates to an additional 235 ft w.g.

Additionally, Variable Speed Drive (VSD) pumps were chosen to reduce pumping utility costs. Sizing of VSD pumps is a greater challenge than sizing single speed pumps because there are several different systems curves. As such, the VSDs were optimally sized for the most common loads. This provides less than ideal efficiencies at peak loads, but in the most common operating band greater savings will be observed. Analysis of shoulder season pumping loads is the simplest way to locate this "sweet spot", and therefore the method we used.

Design and Analysis

After taking into account the building loads a system was selected to best fit the needs of the owner, while considering environmental impacts. Aside from the terminal fan coil and VAV units required by the OPR, the main distinguishing features of our HVAC system design are as follows:

- (x2) Viessmann Vitocrossal 1700 Mbh natural gas condensing boilers with 91% efficiency to reduce fossil fuel use.
- (x1) Airmec 200 ton air-cooled heat recovery chiller with 9.93 EER for reduced electrical consumption footprint.
- (x2) Air handling units with heat pipe air to air heat recovery at 56.2% sensible efficiency to reduce overall heating energy consumption.
- Hydronic radiant heating panels ceiling mounted in ground floor retail space along the perimeter to reduce heating consumption and improve occupant comfort.
- Retained "bonus bedroom" to increase saleable space by locating mechanical equipment in Maint. 113 and on Roof.

The following sections outline the methods behind design choices, energy analysis, and the economic impact analysis.

System Selection

To arrive at the conclusion that a gas-fired boiler and air-cooled chiller plant system is the best choice for the Dallas Power and Light building in the Ottawa climate some preliminary assessments of applicable systems were run. Some systems that are applicable for residential and retail plants in climate Zone 6 that had been considered were:

- Gas-fired boiler and air-cooled or water-cooled chiller
- Gas-fired boiler and absorption chiller
- Ground-source heat pump
- Water-source heat pump
- Air-source heat pump

To determine the most suitable candidate, preliminary energy models were run using eQuest. The early models did not have the room by room detail of the final model, so the zoning was instead broken into percentages of total building area by space type. Different plant equipment was interchanged for the same ASHRAE 90.1-2010 Zone 6 compliant building envelope to limit the variables in the model.

The air-source heat pump would not function at a higher Coefficient of Performance (COP) than 1 in the winter at the design condition (acting as an electric heater), and the water-source heat pump system had higher utility costs than a traditional hydronic boiler and chiller system with higher initial costs. Additionally, the absorption chiller did not pay back when compared to the hydronic boiler and chiller baseline. This narrowed the selection down to either a Ground-source Heat Pump (GSHP) or boiler and chiller system. It was found that due to the requirement of vertical ground wells for the Dallas Power and Light building's cityscape, the payback on the GSHP system over 15 years when compared to a boiler and chiller, which is not a reasonable payback for individually owned residential buildings. When selecting a chiller the limited space for HVAC equipment inside the building (and on the roof) necessitated the use of an air-cooled chiller to save the space that would be required by a cooling tower.

The decision to use a gas-fired boiler and rooftop air-cooled chiller combination was justified by both economics and space constraints. The largest challenge was meeting the needs of the building in the Ottawa climate under the space constraints of a building architecturally designed for Dallas, Texas.

Equipment Selection

As a result of the clients mandate of Fan Coil Units for the suites and VAV Units for the first floor retail, the hydronic plant equipment selection is one of the most critical choices. In the case of Ottawa, Canada, the choice of moving a building designed architecturally for a cooling dominated climate to a heating dominated climate with significant cooling loads presented additional challenges. One of the most prudent was fitting large hydronic equipment within small spaces. This was the motivation behind the choice of a rooftop air-cooled chiller. The limited roof space necessitated using an air-cooled system over a water-cooled one that required an additional cooling tower. In order to make up for our chiller's 9.93 EER, a heat recovery model was implemented to contribute to the heating loads in the shoulder seasons. Analysis of the cost of installing the necessary equipment for the heat recovery chiller gave us a payback period of 13 years and an NPV of \$3,358 over the life of the building. This is with the consideration of additional piping costs and the fuel (natural gas) savings for when the chiller waste heat production was equal or greater than the building heating load so the boiler could be turned down.

Locating the chiller on the roof left room to locate the heating equipment (two Viessmann 1700 Mbtuh boilers) within the ground floor maintenance room. Using the suggested clearances provided by the Viessmann data sheets left little room for other equipment in the space. Additionally, the requirement of heat exchangers to protect the boiler loop from the hydronic loop pressure further pushed the limits of the space. The temperature output of the boilers was chosen to be 167°F (162°F off the heat exchanger) to accommodate both the four pipe fan coil units and the 1st floor radiant panels. As a result, the heating coils of the four pipe fan coil units were oversized to increase the volume of hot water in compensation for the lower temperature and to satisfy the first law of thermodynamics. Fortunately, the cooling coils were the dominant sizing factor in most of the fan coil units, so few had to be upsized from the standard 180°F assumption.

Despite optimal performance of the fan coil units and radiant panels being designed at 180°F or higher, a lower temperature condensing boiler outputting water at 167°F was selected because it could observe up to 91% heating efficiency at lower loads (<50%). This is justified by the fact that the building's loads are heating dominated, so high efficiency heating equipment would provide the largest opportunity for savings. Each boiler (of the 2 boilers) was sized for ~55% of the design block load to allow for simultaneous operation to maintain higher efficiency at lower output, and provide minimum heating if one of the units were to go down.

The largest challenge of the heating equipment design was the ground floor hydronic radiant panels. This subsystem was chosen to complement the ground floor VAV because of the high skin loads from the floor-to-ceiling glazing. Running a lifecycle cost assessment between electric and hydronic radiant panels, it was found that even with combustion losses the hydronic panels were less than half the cost largely due to the higher cost of electricity. Due to the fact that radiant heating can maintain occupant comfort with lower ambient air temperatures, the bulk of the heating load can be moved from the convective VAV system to the higher efficiency radiant panel system. Note that the compromise of a boiler output temperature of 167°F required a larger effective area of radiant panel than at traditional boiler output temperatures (~180°F). In response to the flexibility concerns stated in the OPR, we divided the radiant panels into 3 separate "blocks" for each face of the building (PI-001). This would allow for multiple division scenarios for the Future Tenant Space and allow for sprinkler and light fixture installation. A detailed comfort analysis that conveys compliance to ASHRAE 55 is outlined for the south-facing portion of Future Tenant 104 in the ASHRAE 55 compliance section.

For air handling, Engineered Air custom air handling units were chosen. They are equipped with heat pipe sensible heat recovery coils that have 56.2% sensible efficiency for air to air heat recovery supplying both the suite fan coil makeup air and first floor VAV systems. This "zero contamination" heat recovery system allowed us to harvest the waste heat from both the kitchen and the washroom exhaust for preheat, despite the Class 4 Air designation of washroom exhaust, by

mixing the airstreams at the rooftop plenum. This doubled the amount of exhaust air that could be recovered, which more than makes up for the loss of latent heat and lower efficiency compared to an enthalpy wheel. Additionally, the passive nature of heat pipes reduces their maintenance and control costs when compared to active heat recovery systems such as heat wheels. Due to the lower size of the first floor VAV system, the same style of air handling unit was used to reduce design costs and ease maintenance.

The cold Ottawa winters caused the water content of the outdoor air to be quite low. This brought the indoor Relative Humidity down to 20%. To mitigate the air dryness, and increase occupant comfort, an electric air handling unit humidifier was installed in the Dedicated Outdoor Air Supply (DOAS) unit supplying the suites to humidify the air between 30% and 60% RH. The hot water is supplied from the service water line. The first floor air handling unit was not equipped with a humidifier because of space constraints. This is generally acceptable because the retail spaces will see more infiltration than the suites and will have shorter periods of occupancy.

Seven different models of Trane fan coil units were selected to condition the suites. All of these units operate at or below Noise Criteria (NC) 30 at 8000 Hz. Six custom VAV units were selected for the first floor that operate below NC 45.

On the delivery side of the system, high efficiency VSD pumps and fans were selected to allow modulation and save energy over the lifetime of the building. VSDs will also allow lower operating pressures in the piping and ducting, which will decrease the amount of noise and increase their usable life. The selection of the optimal efficiency band was based on the shoulder seasons and most common loads, since that is where the pump and fan curves will most likely reside. Peak loads will experience lower efficiencies, but their occurrence is significantly lower in comparison.

Energy Analysis

With all end uses considered, the HVAC design's total (gas and electric) Energy Use Intensity (EUI) was 181 kWh/m² and the Greenhouse Gas (GHG) intensity was 0.0028 tons CO₂e/ft². Total energy consumption comparison and GHG breakdowns against our two alternatives can be seen in Figure 7 and Figure 8 respectively. For monthly heating and cooling breakdowns, as well as end use breakdown, please refer to Figure 5 and Figure 6 in the Modeling section on Page 3.




Figure 7: Comparison of Annual Energy Consumption for Our Design and Two Alternatives

As can be seen in Figure 7, 9.0% energy savings was achieved from the ASHRAE 90.1-2010 baseline. These savings can be entirely attributed to the HVAC system equipment choices because we used the assumption of ASHRAE 90.1-2010 minimum envelope construction. Our choice of a high efficiency boiler is the driving force behind these savings due to the building being located in a climate with large heating requirements. Additionally, the use of triple paned windows

(in place of double paned) would see 17.5% energy savings from ASHRAE 90.1-2010, which could justify Leadership in Energy and Environmental Design (LEED) points if certification is desired by the owner.

The design also reduced GHG emissions by 9.5% when compared to the ASHRAE 90.1-2010 baseline. Adding triple paned windows to the design would bring the GHG emissions down by 18.0% when compared to the baseline. The bulk of these reductions are seen by either increasing boiler combustion efficiency or reducing heating loads because the emission factor for natural gas combustion is significantly higher than for Ontario Hydro electrical consumption.

Economic Analysis

When the utility rates provided in the Utility and Service Life Overview (see Input Summary Table in Modeling on Page 3) were applied, our design saved \$4,800 (7.4%) annually from the ASHRAE baseline. While this currently doesn't meet LEED prerequisite requirements using ASHRAE 90.1 minimum envelope conditions, the addition of triple paned windows would yield 16.2% energy cost savings which would enable LEED NC 2009 credits. Using the guidelines in the OPR we saw significant savings, but in the sub-arctic climate of Zone 6, triple paned windows would be a worthwhile investment. Comparisons of the annual utility costs between our design and our two ECMs can be seen in Figure 9.

The two hydronic gas-fired boilers and rooftop air cooled chiller had capital costs of \$106,000 and \$222,000 respectively. The boilers were the more reasonably priced component given the capacity that we required and the heating savings. The air cooled chiller was a necessity to fit all of the mechanical equipment within the space given by the architectural drawings. Rooftop enclosures were not an option without significant architectural and structural changes to the building that were beyond the scope of this project. Part of the cost of the chiller was to add the heat recovery option. To confirm the validity of this design choice, we ran a net present value calculation using a lifetime of 25 years and the interest rates given in the Utility and Service Life Overview. Considering the heating savings and capital costs of the equipment required for an additional loop, we found the addition of the heat recovery chiller line to have a net present value of \$3,350. A positive net present value justifies this design choice.




Figure 8: Comparison of Annual GHG Emissions for Our Design and Two Alternatives




Figure 9: Comparison of Annual Utility Costs for Our Design and Two Alternatives

Economic analysis was also run for the 1st floor radiant panels to compare electric with hydronic versions. We found when maintenance, operating costs, and capital costs were considered, the electric panels had a lifetime cost of \$180,500, and the hydronic panels had a lifetime cost of \$83,700. This provided the justification for choosing hydronic panels, since they were less than half the cost of electric.

Addressing the building owner's desire for apartment owners to be responsible for individual energy usage, it is proposed that the utilities costs for the central plant be collected through a "maintenance fee". This fee would include the tenant's portion of the electrical and gas consumption determined by a ratio of suite square feet to the building total. This would then be applied to the building's total energy cost from the utility provider. The fee would account primarily for heating, cooling, and common area lighting utility costs, and would be administered monthly. This route was chosen to save the cost of installing hydronic energy meters, and avoid the requirement of the strata to be a Regulated Utility Provider. The electrical energy for the individual suite fan coils would be routed through the suite's electrical meter, so the tenant will pay for their own fan coils operation.

All economical choices were based on either lifetime costs, or in the case of the chiller, selecting a product that meets the unique needs of our project. If the Dallas Power and Light building were designed for the Ottawa climate, it is very likely that the mechanical space would have been larger than for Dallas. As a result, our choice to use the climate of our nation's capital provided an additional challenge that pushed the physical and economical feasibility of this project.

ASHRAE Standard Compliance

ASHRAE 55

To demonstrate our knowledge of ASHRAE 55-2010, a thermal comfort calculation was performed that demonstrates the first floor retail's radiant panel effectiveness. The temperature assumptions, and the governing equations are as follows:

$$T_{mean\ radiant}^4 = \sum F_{x-occupant} T_x^4 \quad T_{operative} = (T_{mean\ radiant} + T_{ambient})/2$$

The angle factors (F_x) and temperatures (T_x) we assumed are:

	Exterior Wall	Exterior Window	Radiant Panel Surface	Imaginary Surfaces
Angle Factor	0.147	0.027	0.176	0.650
Temperature (°F)	63.5	42.5	132.0	64.0

The geometries for the angle factor calculation were taken from Figure 10 and the elevation drawings under the assumption that the occupant is located in the center of the zone, and their center of mass is 2 feet above the floor (sitting position). The "imaginary surfaces" are a representation of the distant walls and roof that would be at roughly ambient air temperature which allows splitting of the space along the lines in Figure 10. The geometries were then used with the tables in Figure 11 to find the angle factors for the mean radiant temperature ($T_{\text{mean radiant}}$) calculation. The temperatures used were calculated using a combination of model output data and hand calculations to account for re-radiated heat and radiant panel thermal resistance. Note that the temperature gains of the floor from re-radiated heat were negligible due to the heavy thermal mass (similar to the walls), so it was assumed to be part of the ambient temperature surface (64°F).




Figure 10: First Floor Retail South Zone Geometry Relative to Occupant




Figure 11: Angle Factor Tables from ASHRAE Fundamentals 2009

Applying the figures and calculations yielded an Operative Temperature ($T_{\text{operative}}$) of 71.5°F at design conditions where the RH is 20% in the retail space. The resulting $T_{\text{operative}}$ and RH are represented by a red dot in Figure 12. This demonstrates that our design meets the criteria of ASHRAE 55-2010 for the heating season under the assumption of mild activity and winter clothing accumulating to 1.0 clo for the retail space.

ASHRAE 62.1

In order to verify the model's compliance with ASHRAE 62.1-2010, a spreadsheet was used to compare the model outdoor air flow rates with the rates prescribed by the standard. A summary of the outdoor air calculation results can be seen in Table 8. The 25% difference can be attributed to safety factors within the software, and infiltration losses. Additionally, having higher than minimum outdoor air is acceptable because the building needs to be positively pressurized.

Table 8: Comparison of Outdoor Air Requirement Between Model and Hand Calculation

	OA (cfm)
Calculated	9383
Model	12500
% Difference	25%




Figure 12: Acceptable Range of Operating Conditions for Spaces that Meet ASHRAE 55-2010 Section 5.2.1.1

ASHRAE 90.1

ASHRAE 90.1-2010 was used as a baseline standard for assumption about the building envelope and lighting loads, and for equipment efficiencies to compare performance. All of the hydronic and air handling equipment meet the minimum requirements of ASHRAE 90.1-2010 as per the OPR. The assumptions for lighting power density can be seen in Table 3. A brief comparison of equipment efficiencies and ASHRAE minima are outlined in Table 9.

Table 9: ASHRAE 90.1-2010 Equipment Efficiency Comparison

	Type	Design Efficiency	ASHRAE 90.1-2010 Minimum
Heating	Gas-fired hot water boiler	91%	80%
Cooling	Air cooled chiller	9.93 EER	9.562 EER
Heat Recovery	Heat pipe air-to air	56.2%	50%
Domestic Water Heater	Gas-fired storage tank heater	96%	80%

Conclusion

The UBC ASHRAE Student Design Team put the utmost care into designing a HVAC system that meets the needs of the Dallas Power and Light Building owner and the judging committee, and complies to ASHRAE 55-2010, ASHRAE 62.1-2010, and ASHRAE 90.1-2010. Energy efficiency and economics were also significant considerations. Where possible, payback and net present value analysis was applied to justify design decisions that could reduce operating and maintenance costs. The largest challenge of this project was retooling the HVAC system of a building architecturally designed for a cooling dominant climate to operate efficiently in a heating dominant climate. Mechanical spaces were clearly designed for much smaller heating equipment, which limited the space we had for cooling equipment. As a result, a rooftop air-cooled chiller was used to conserve the mechanical space on the first floor that houses the boilers and their support equipment. Air to air heat pipes were used for heat recovery because they provide minimal leakage and are a passive technology. These features allow energy recovery from washroom exhaust, and reduce maintenance costs. High efficiency boilers were also implemented to save energy on the building's largest energy load. With the annual energy savings from the boilers, they could pay for themselves within the lifetime of the building.

The condensing gas-fired boiler and air-cooled heat recovery chiller system provides a very energy efficient plant equipment solution given the limited mechanical space available and terminal unit requirements. When compared to heat pump based systems, its installation cost is significantly less because cooling towers are not required (water-source) and there is no need for ground well installation and geotechnical analysis (ground-source). The chiller selection did not result in a particularly high EER, but its rooftop placement allowed more significant savings from the high efficiency boilers. Some additional justification for the chiller selection is the heat recovery functionality that provides essentially free heating during the shoulder seasons.

In closing, the UBC ASHRAE Design Team learned a great deal about HVAC design from this project. The opportunity of working with different people in industry and within the team proved to be as valuable an experience as the technical learning aspect. In the world of HVAC design consulting, being skilled at all three of those aspects is essential to both the success of yourself and the industry as a whole.

Acknowledgments

We would like to thank Dr. Nima Atabaki, Dr. Steven Rogak, and Geoff McDonell for their help that led to the success of this project. Dr. Nima Atabaki is an instructor at UBC who provided in-depth technical insight and recommendations for our design. Dr. Steven Rogak is a professor at UBC who provided us guidance with respect to major milestones and general presentation. Geoff McDonell is an Associate Principle at Integral Group that provided valuable industry knowledge and regular technical review. Without their help this project would not have been possible.

References

2011 ASHRAE Handbook - *Heating, Ventilating, and Air-Conditioning Applications (I-P Edition)*. (2011). American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

2009 ASHRAE Handbook - *Fundamentals (I-P Edition.)* (2009). American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE). (2006). *ASHRAE Green Guide, second edition*.

American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE). (2012).

The 2013 design competition instructions. Retrieved Sept/10, 2012, from <https://www.ashrae.org/membership--conferences/student-zone/design-competition>

ASHRAE 55-2010. (2010). *Thermal Environmental Conditions for Human Occupancy*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ASHRAE 62.1-2010. (2010). *Ventilation for Acceptable Indoor Air Quality*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ASHRAE 90.1-2010. (2010). *Energy Standard for Buildings Except Low-Rise Residential Buildings*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

British Columbia Ministry of Environment. (2012). *Methodology for Quantifying Greenhouse Gas Emissions*.

Trane . (2012). Varitrane™ duct designer.


Retrieved Jan/22, 2013, from Product Help Menu

Trane. (2012). TRACE® 700 Users Manual


Retrieved Jan/10, 2013, from Product Help Menu

Trane. (2012). Trane Pipe Designer.


Retrieved Jan/22, 2013, from Product Help Menu



GROUND FLOOR
NTS




SECOND FLOOR
NTS




TRUE NORTH
PLAN NORTH

REV 0		ISSUED TO ASHRAE COMPETITION	
No.		REVISION	
DRAWN BY	DATE	UBC ASHRAE TEAM	
AW	13/04/01		
CHECKED	DATE		
BY		DUCTING SYSTEMS - GROUND FLOOR AND 2ND FLOOR	
		DRAWING NO.	REV
		D-001	0


FOURTH FLOOR
NTS

REV 0	ISSUED TO ASHRAE COMPETITION
No.	REVISION
DRAWN BY	DATE
AW	13/04/01
CHECKED	DATE
BT	
DUCTING SYSTEMS - THIRD FLOOR AND FOURTH FLOOR	
DRAWING NO.	
D-002	REV
	0




SEVENTH FLOOR
NTS


TENTH FLOOR
NTS



REV 0		ISSUED TO ASHRAE COMPETITION	
No.	DATE	REVISION	
AW	1304/01	UBC ASHRAE TEAM	
CHECKED BY	DATE	DUCTING SYSTEMS - SEVENTH FLOOR AND TENTH FLOOR	
		DRAWING NO.	REV
		D-003	0





TWELFTH FLOOR
NTS




SEVENTEENTH FLOOR
NTS

REV 0	ISSUED TO ASHRAE COMPETITION	
	REVISION	
	UBC ASHRAE TEAM	
DRAWN BY	DATE	
AW	13/04/01	
CHECKED BY	DATE	
PIPING SYSTEMS - TWELFTH FLOOR AND SEVENTEENTH FLOOR		
DRAWING NO.		REV
D-004		0






EIGHTEENTH FLOOR
NTS




NINETEENTH FLOOR
NTS




REV 0		ISSUED TO ASHRAE COMPETITION	
No.	DATE	REVISION	
AW	1304/04		
CHECKED BY	DATE		
DRAWING NO. D-005			
REV 0			


UBC ASHRAE TEAM
DUCTING SYSTEMS - EIGHTEENTH
FLOOR AND NINETEENTH FLOOR



ROOF
NTS



TWENTIETH FLOOR
NTS




REV 0		ISSUED TO ASHRAE COMPETITION	
No.	REVISION	UBC ASHRAE TEAM	
Drawn By	Date		
AW	13/04/04		
Checked	Date	DUCTING SYSTEMS - TWENTIETH FLOOR AND ROOF	
By			
		Drawing No.	REV
		D-006	0

MIN: 425 CFM
MAX: 3188 CFM

RISER B

4250 CFM




KITCHEN EXHAUST RISERS

LEVEL 1

MIN: 250 CFM
MAX: 1875 CFM

RISER 2

2500 CFM



BATHROOM EXHAUST RISERS

LEVEL 1

LEVEL 2

LEVEL 3

LEVEL 4

LEVEL 5

LEVEL 6

LEVEL 7

LEVEL 8

LEVEL 9

LEVEL 10

LEVEL 11

LEVEL 12

LEVEL 13

LEVEL 14

LEVEL 15

LEVEL 16

LEVEL 17

LEVEL 18

LEVEL 19

LEVEL 20

ROOF

REV 0 ISSUED TO ASHRAE COMPETITION

No. REVISION

UBC ASHRAE TEAM

DUCTING SYSTEMS - SCHEMATIC
EXHAUST FLOW DIAGRAM

DRAWING NO.

D-007

REV

0

Exhaust Fans


Tag	EF-1	EF-2	REF-1	REF-2	REF-3
Service					
Location	Bathroom	Kitchen	Roof-Kitchen	Roof-Bathroom 1	Roof-Bathroom 2
Airflow (CFM/ l/s)	50	50	3188	1875	1913
Total SP (ins WC/Pa)	0.05	1.05	0.445	0.501	0.501
External (Discharge)			0.612	0.665	0.665
SP (ins WC/Pa)					
Fan Hp (Kw)			1/2	1/4	1/4
Fan Speed (RPM)			888	562	755
Electrical		120			
(Volts/Ph/hz)					
Sound Level (Sones)	0.8	4.1	11	4.1	6.5
Make	BROAN	BROAN	GREENHECK	GREENHECK	GREENHECK
Model	QTR080C2S	BDF302SS	LB-18-5	LB-18-4	LB-18-4
Notes/Options					

Air Terminal and Louvres Schedule


Tag:	Make	Model	Installation	Notes
SD-1	E.H. PRICE	PDS Series	Lay-in	
SD-2	E.H. PRICE	STG1 Series	In wall	
SD-3	E.H. PRICE	DFGL Series	Underfloor	
RD-1	E.H. PRICE	PDR Series	Lay-in	




REV 0		ISSUED TO ASHRAE COMPETITION	
No.		REVISION	
DRAWN BY	DATE	UBC ASHRAE TEAM	
AW	02/04/13		
CHECKED	DATE		
BY		DUCTING SYSTEMS - SCHEMATIC SUPPLY FLOW DIAGRAM & SCHEDULE	
		DRAWING NO.	REV
		D-008	0



GROUND FLOOR
NTS





SECOND FLOOR
NTS




University of
British Columbia
Student Edition


ISSUED TO ASHRAE COMPETITION	
REVISION	
UBC ASHRAE TEAM	
PIPING SYSTEMS - GROUND FLOOR AND 2ND FLOOR	




THIRD FLOOR
NTS

FOURTH FLOOR
NTS

REV 0	ISSUED TO ASHRAE COMPETITION
No.	REVISION
DRAWN BY	UBC ASHRAE TEAM
DATE	
GW	13/04/26
CHECKED BY	
DATE	
	PIPING SYSTEMS - THIRD FLOOR AND FOURTH FLOOR
 ASHRAE University of British Columbia Student Branch	DRAWING NO.
	REV
	PI-002 0




SEVENTH FLOOR
NTS





TENTH FLOOR
NTS

REV 0		ISSUED TO ASHRAE COMPETITION	
No.		REVISION	
DRAWN BY	DATE	UBC ASHRAE TEAM	
GW	13/04/26		
CHECKED BY	DATE		
		DRAWING NO.	
		PIPING SYSTEMS - SEVENTH FLOOR AND TENTH FLOOR	
		REV	
		0	



University of
British Columbia
Student Edition



TWELFTH FLOOR
NTS


SEVENTEENTH FLOOR
NTS



REV 0	ISSUED TO ASHRAE COMPETITION	
	No.	REVISION



DRAWN BY	DATE
GW	13/04/26
CHECKED BY	DATE

PIPING SYSTEMS - TWELFTH FLOOR
AND SEVENTEENTH FLOOR


ASHRAE	
University of British Columbia	Student Edition





REV 0	ISSUED TO ASHRAE COMPETITION
No.	REVISION
DRAWN BY	DATE
GW	13/04/26
CHECKED BY	DATE
	
	
<p>PIPING SYSTEMS - EIGHTEENTH FLOOR AND NINETEENTH FLOOR</p>	
DRAWING NO.	REV
PL-005	0


MECHANICAL SYMBOLS AND ABBREVIATIONS




Pumps

Tag	P-1	P-2	P-3
Service	HWL	CWL	HWL Heat Recovery
Location	Maint. 113	Roof	Maint. 113
Type	Vertical Inline Centrifugal with VSD	Vertical Inline Centrifugal with VSD	Vertical Inline Centrifugal with VSD
Flow (gpm)	277	96	153 gpm
Head (Ft)	285	37	9.84
Motor Hp. (Kw)	27	3.5	0.44
Pump Speed (RPM)	3550	2990	1450
Electrical (Volts/Phase/Hz)	110/3/60	110/3/60	110/3/60
Impeller Size (Ins.)	8.7	4.84	4.84
Efficiency	58%	76%	70%
Make	Armstrong 4302	Armstrong 4302	Armstrong 4302
Model	150-250	100-150	150-150
Pump Size	150-250	100-150	150-150
Notes/Options			

- Notes/Options:
- All bronze construction.
 - C/w quick connect electrical connection (twist-lock or equal).




COOLING WATER RISERS
NTS



HEATING WATER RISERS
NTS

REV 0		ISSUED TO ASHRAE COMPETITION	
No.	REVISION		
DRAWN BY	DATE		
GW	13/05/02	UBC ASHRAE TEAM	
CHECKED BY	DATE		
		PIPING SYSTEMS - SCHEMATIC FLOW DIAGRAM	
		DRAWING NO.	REV
		P1-006	0

GENERAL NOTES:
- NOMINAL COOLING SUPPLY AIR TEMPERATURE BASED ON 56°F WITH 78°F RETURN AIR TEMPERATURE
- NOMINAL HEATING SUPPLY AIR TEMPERATURE / CAPACITY BASED ON 72°F RETURN AIR TEMPERATURE
- NOMINAL TOTAL MAXIMUM AIR PRESSURE DROP THROUGH COIL SHALL BE NOT MORE THAN 0.75" W.C. (187 Pa)



FAN COIL UNIT INSTALLATION DETAIL
SCALE NTS

VAV Terminal Units

Tag	Service	VAV-A	VAV-B	VAV-C	VAV-D	VAV-E	VAV-F
	L1 Auxiliary Spaces	L1 Tenant Rm.	L1 Tenant 103	L1 Tenant 104 Core	L1 Tenant 104 South	L1 Tenant 104 West	L1 Tenant 104 West
	Location	Elevator Lobby 100	Maint. 113	Elevator Lobby 100	Future Tenant 104	Future Tenant 104	Future Tenant 104
Air Side Data:							
Airflow (cm)		1000-350	100-50	650-200	650-200	1400-500	2400-700
External SP		0.26	0.02	0.32	0.32	0.26	0.35
(ins.WC)							
Cooling Mode Ent.		57/56	57/56	57/56	57/56	57/56	57/56
Air Temp. DBWB							
Heating Mode Ent.		56	56	56	56	56	56
Air Temp. DB (F)							
Heating Mode Lvg		77	99	79	81	80	86
Air Temp. DB (F)							
Water Side Data:							
Heating Flow		0.6	0.3	0.43	0.38	0.81	1.68
(USgpm)							
Heating EVLT (F)		160	160	160	160	160	160
Heating LWT (F)		130	140	130	130	130	130
Press. Drop (Ft. head)		0.08	0.07	0.16	0.13	0.16	3.15
Make		EH Price	EH Price	EH Price	EH Price	EH Price	EH Price
Model		SDV5	SDV5	SDV5	SDV5	SDV5	SDV5

Heating Coils

Tag	Service	HC-1	HC-2
	Location	AHU-1 Roof	AHU-2 Loading Area 111
Airflow (CFM)		12650	6100
Air Pressure Drop		0.09	0.05
(ins.WC)			
Face Velocity (Fpm)		448	379
Air On Temperature		27.4	38.5
DB (F)		72.2	70.6
Air Off Temperature			
DB (F)			
Total Load (Btu/h)		612490	211300
Water Flow (gpm)		60.0	160.0
EWLT (F)		160.0	139.6
LWT (F)		139.2	139.6
WPD (Ft. head)		2.8	2.7
Make		Engineered Air	Engineered Air
Model		Custom	Custom

Notes/Options:
Common to all coils: Coil supplier shall select rows and fin spacing based on the above performance data.

Chiller – Air Cooled

Tag	Service	CH-1
	Location	All
Total Cooling Load (Tons)		200
Ambient Air DBWB (F)		95
Min. Stages of Cooling		1
EWLT (F)		57
LWT (F)		44
CHW Flow (USgpm)		490
Water PD (Ft. Head)		25
Running Load Amps		313.1
Electrical (Volts/Phase/Hz)		575/3/60
Refrigerant Type		R410a
Refrigerant Compressor Type		Scroll
Sound Power Level- Radiated (dBA)		66
Full Load Efficiency (kW/Ton)		1.208
Make		AERMEC
Model		NRI2900071A00800
Notes/Options:		Full Heat Recovery/Included

- Notes/Options:
1. C/w solid state control panel with starters(s) with dry contact (or equal) terminal strip for Building Automation System (BAS) connection to read all operating characteristics of unit.
2. C/w all standard factory mounted pressure and temperature sensing and control connections, pressure relief valve(s), flow switch(es), disconnect switch (for field mounting by Div. 16).

Tag	Service	AHU-1	AHU-2
	Location	Corro Suites (L2-L20)	1st Floor Retail (L1)
Supply Air Side:			
Airflow (CFM)		12650	6100 (+1700 relief)
Total Static Press. (ins.WC)		1.88	1.98
Fan Hp		7.5	5
Exhaust Air Side:			
Airflow (CFM)		9500	7900
Total Static Press. (ins.WC)		1.97	1.54
External SP (ins.WC)		0.5	0.5
Fan Hp		7.5	5
Make		Engineered Air	Engineered Air
Model		Custom w Heat Pipes	Custom w Heat Pipes
Notes/Options:		Custom	Custom

- Notes/Options:
1. Complete with one set of spare filters to be turned over to Owner at Substantial Performance point.
2. C/w extended lube lines (pre-charged at factory) to exterior of AHU Casing with labels.

Fan Coil Units

Tag	Service	FC201	FC301	FC401	FC801	FC803	FC1001	FC1203
	Location	Various Suites	Various Suites	Various Suites	Various Suites	Various Suites	Various Suites	Various Suites
Air Side Data:								
Airflow (cfm)		246	313	381	609	676	1015	993
External SP (ins.WC)		0.05	0.05	0.05	0.05	0.05	0.05	0.05
Cooling Mode Ent. Air Temp. DB (F)		67	67	67	67	67	67	67
Heating Mode Ent. Air Temp. DB (F)		70	70	70	70	70	70	70
Fan Motor Power (W/Als)		37	39	58	79	122	145	160
Electrical (Volts/Phase/Hz)		115/1/60	115/1/60	115/1/60	115/1/60	115/1/60	115/1/60	115/1/60
Water Side Data:								
Cooling Flow (USgpm)		1.2	1.4	1.7	3.0	4.0	5.3	6.1
Cooling EVLT (F)		45	45	45	45	45	45	45
Press. Drop (Ft. head)		7.75	9.79	3.39	11.45	6.95	11.15	10.39
Heating Flow (USgpm)		0.6	0.7	0.9	1.5	1.8	2.8	2.7
Heating EVLT (F)		160	160	160	160	160	160	160
Press. Drop (Ft. head)		0.95	1.23	2.25	6.82	11.35	36.37	32.29
Make		Triane	Triane	Triane	Triane	Triane	Triane	Triane
Model		Cancelled	Cancelled	Cancelled	Cancelled	Cancelled	Cancelled	Cancelled

Heat Recovery

Tag	Service	HR-1	HR-2
	Location	Corro Suites (L2-L20)	1st Floor Retail (L1)
Type		AHU -1	AHU -2
Heating Side:			
Incoming Temperature DBRH (F %)		72.0/50	72.0/50
Leaving Temp. DBRH (F %)		36.9/100	35.0/100
Flow (cm)		9500	6100
Pressure Drop (ins.WC)		0.67	0.49
Heated Side:			
Incoming Temperature DBRH (F %)		-12.0/80	-12.0/80
Leaving Temp. DBRH (F %)		27.4/11	35.5/05
Flow (cm)		12650	6100
Pressure Drop (ins.WC)		0.52	0.36
Total Load (Btu/h)		538400	332800
Cooling Side:			
Incoming Temperature DBRH (F %)		74.80	74.80
Leaving Temp. DBRH (F %)		83.8/43	81.7/45
Flow (cm)		9500	6100
Pressure Drop (ins.WC)		0.60	0.44
Cooled Side:			
Incoming Temperature DBRH (F %)		87.1/40	87.1/40
Leaving Temp. DBRH (F %)		79.7/57	79.7/57
Flow (cm)		12650	6100
Pressure Drop (ins.WC)		0.60	0.44
Total Load (Btu/h)		100600	50800
Make		Engineered Air	Engineered Air
Model		Custom	Custom

- Notes/Options:
1. C/w stainless steel drain pan under all coil/plat sections.
2. C/w minimum 24"x24" (600x600mm) access doors at connecting ductwork for cleaning access.
3. C/w air filters on incoming air side and leaving air side, see Specifications and drawings.

Cooling Coils

Tag	Service	CC-1	CC-2
	Location	AHU-1 Roof	AHU-2 Loading Area 111
Airflow (CFM)		9500	6100
Air Pressure Drop (ins.WC)		0.09	0.39
Face Velocity (Fpm)		355	373
Air On Temperature DBWB (F)		79.7/68.6	79.4/68.5
Air Off Temperature DBWB (F)		72.0/65.5	57.2/56.6
Total Load (Btu/h)		103160	238230
Sensible Load (Btu/h)		78910	148350
Water Flow (gpm)		20.8	49.9
EWLT (F)		45	45.0
LWT (F)		54.9	54.4
WPD (Ft. head)		2.5	5.4
Make		Engineered Air	Engineered Air
Model		Custom	Custom

- Notes/Options:
Common to all coils: Coil supplier shall select rows and fin spacing based on the above performance data. All Refrigerant coils for variable air volume systems shall be alternate row arrangement for matched # of refrigerant coils/stages.
1. C/w stainless steel drain pan.
2. C/w epoxy painted steel drain pan.

Heat Exchangers - Fluid Type

Tag	Service	HE X-1	HE X-2
	Location	Boiler 1 Maint. 111	Boiler 2 Maint. 111
Type		Plate	Plate
Heating Side:			
Medium		Hot Water	Hot Water
Incoming Temp. (F)		167	167
Leaving Temp. (F)		140	140
Flow (gpm)		148.0	148.0
Pressure Drop (Ft. Head)		8.05	8.05
Heated Side:			
Medium		Hot Water	Hot Water
Incoming Temp. (F)		135	135
Leaving Temp. (F)		152	152
Flow (gpm)		15.2	15.2
Pressure Drop (Ft. Head)		8.54	8.54
Total Load (Btu/h)		195000	195000
Make		GFA	GFA
Model		NT50X	NT50X
Pressure Rating (Psi)		300	300

- Notes/Options:
1. C/w pressure relief valves on primary fluid and secondary fluid pipes.
2. C/w one spare set of gaskets to be turned over to Owner at Substantial Performance.
3. C/w bor or wall rack/stand as required for specific installation.

Expansion Tanks

Tag	Service	ET-1	ET-2
Location	C/W Line	Roof	H/W Line
Acceptance Volume (USGal)	2.4	Roof	11.3
Total Volume (USGal)	8		21.7
Pie-Charge Pressure (Psi)	12		12
Height (ins.)	19.5		29.5
Diameter (ins.)	12		16.5
Make	Amrad		Amrad
Model	AX-15(V)		AX-40(V)
Notes/Options:			

- Notes/Options:
1. C/w floor stand and seismic restraint strap to wall anchors.
2. C/w hanging saddles for suspended horizontal installation.
3. C/w spare gasket and/or bladder to be turned over to Owner at Substantial Performance.

Suspended Radiant Panels

Tag	Service	RP-1
	Location	Retail Space Future Tenant 104
Ambient Air (F)		68
Heating Mode Ent.		160
Heating LWT (F)		75
Press. Drop (Ft. head)		0.5
Heating Capacity (Btu/h per sq.ft)		360
Notes/Options:		Heating Only



System Checksums

By ACADEMIC

L1 Tenant 104 S

VAV w/Baseboard Skin Heating

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES					
Peak'd at Time: Month: 8 / 15					Month: 8 / 15					Month: Heating Design										
Outside Air: OADB/MBHR: 83 / 74 / 111					OADB: 83					OADB: -9										
Sens + Lat	Space	Plenum	Net	Percent	Sens + Lat	Space	Plenum	Net	Percent	Sens + Lat	Space	Plenum	Net	Percent	Sens + Lat	Space	Plenum	Net	Percent	
BuIn	BuIn	BuIn	OT Total	(%)	BuIn	BuIn	BuIn	OT Total	(%)	BuIn	BuIn	BuIn	OT Total	(%)	BuIn	BuIn	BuIn	OT Total	(%)	
Envelope Loads	0	0	0	0	Envelope Loads	0	0	0	0	Envelope Loads	0	0	0	0	SAOB	0	0	0	0	
Sky/Solar	0	0	0	0	Sky/Solar	0	0	0	0	Sky/Solar	0	0	0	0	Ra Plenum	75.6	75.6	0	0	
Sky/Solar Cond	0	0	0	0	Sky/Solar Cond	0	0	0	0	Sky/Solar Cond	0	0	0	0	Return	75.6	75.6	0	0	
Road Cond	0	0	0	0	Road Cond	0	0	0	0	Road Cond	0	0	0	0	RadiOA	78.2	0.1	0	0	
Glass Solar	20.875	0	20.875	24	Glass Solar	20.875	49	20.875	24	Glass Solar	-20.279	0	-20.279	18.69	Fn MTRD	0.2	0.2	0	0	
Glass/Door Cond	5.107	0	5.107	6	Glass/Door Cond	5.107	12	5.107	6	Glass/Door Cond	-12.007	0	-12.007	10.09	Fn Frict	0.6	0.6	0	0	
Wall Cond	4.389	0	4.389	6	Wall Cond	4.389	10	4.389	6	Wall Cond	-10.017	0	-10.017	8.38	Fn Infil	0.6	0.6	0	0	
Partition/Door	0	0	0	0	Partition/Door	0	0	0	0	Partition/Door	0	0	0	0	AIRFLOWS					
Floor	-1.316	0	-1.316	-2	Floor	-1.316	-3	-1.316	-2	Floor	-26.991	0	-26.991	22.67	Diffuser	1.431	1.431	429	429	
Adjacent Floor	0	0	0	0	Adjacent Floor	0	0	0	0	Adjacent Floor	0	0	0	0	Terminal	1.431	1.431	429	429	
Infiltration	11.689	0	11.689	14	Infiltration	11.689	14	11.689	14	Infiltration	-24.292	0	-24.292	20.31	Main Fan	0	0	0	0	
Sub Total ==>	40.544	699	41.143	49	Sub Total ==>	31.547	73	31.547	49	Sub Total ==>	-82.178	69.94	-83.629	69.94	Non Vent	514	514	429	429	
Internal Loads					Internal Loads					Internal Loads					AHU Vent					
Lights	2.424	606	3.031	4	Lights	2.424	6	2.424	4	Lights	0	0	0	0	Infil	283	283	429	429	
People	17.998	0	17.998	21	People	17.998	21	17.998	21	People	0	0	0	0	MinStop/Rn	429	429	429	429	
Misc	0	0	0	0	Misc	0	0	0	0	Misc	0	0	0	0	Return	1.714	1.714	712	712	
Sub Total ==>	20.423	606	21.029	26	Sub Total ==>	11.477	27	11.477	26	Sub Total ==>	0	0	0	0	Rm Exh	797	797	0	0	
Ceiling Load	239	-239	0	0	Ceiling Load	239	1	239	0	Ceiling Load	-541	0	-541	0	Auxiliary	0	0	0	0	
Ventilation Load	0	0	0	0	Ventilation Load	0	0	0	0	Ventilation Load	0	0	0	0	Leakage Dwn	0	0	0	0	
Aq Air Trans Heat	0	0	0	0	Aq Air Trans Heat	0	0	0	0	Aq Air Trans Heat	0	0	0	0	Leakage Ups	0	0	0	0	
Dehumid Ov Sizing	0	0	0	0	Dehumid Ov Sizing	0	0	0	0	Dehumid Ov Sizing	0	0	0	0	ENGINEERING CKS					
Exhaust Heat	-449	-449	0	0	Exhaust Heat	-449	0	-449	0	Exhaust Heat	0	0	0	0	% OA	Cooling	35.8	Heating	100.0	100.0
Sup Fan Heat	1.451	1.451	0	0	Sup Fan Heat	1.451	2	1.451	0	Sup Fan Heat	0	0	0	0	chmFt	0.66	0.29	0.29	0.29	
Reet Fan Heat	0	0	0	0	Reet Fan Heat	0	0	0	0	Reet Fan Heat	0	0	0	0	chmFt	203.49	211.75	211.75	211.75	
Duct Heat Pump	0	0	0	0	Duct Heat Pump	0	0	0	0	Duct Heat Pump	0	0	0	0	fr/tion	69.67	69.67	-28.31	-28.31	
Underfrt Sup Ht Pump	0	0	0	0	Underfrt Sup Ht Pump	0	0	0	0	Underfrt Sup Ht Pump	0	0	0	0	BuInHt-Ft	45	45	45	45	
Supply Air Leakage	0	0	0	0	Supply Air Leakage	0	0	0	0	Supply Air Leakage	0	0	0	0	No. People					
Grand Total ==>	61.205	517	84.412	100.00	Grand Total ==>	43.062	100.00	43.062	100.00	Grand Total ==>	-82.219	-119.678	100.00							

Project Name: DP&L Building
Dataset Name: DP&L_v11.trc
TRACES® 700 v6.2.8 calculated at 06:15 PM on 04/01/2013
Alternative - 1 System Checksums Report Page 5 of 105

COOLING COIL SELECTION					HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/MBHR	Leave DB/MBHR	Gross Total	Glass	Main Htg	Aux Htg	Humidtr
ton	MBH	cfm	F	F	ft ²	(%)	MBH	cfm	gr/s
Main Ctg	7.0	84.4	49.6	78.2	1,490	0	0.0	0	0.0
Aux Ctg	0.0	0.0	0.0	0.0	Part	0	-82.7	0	0.0
Opt Vent	0.0	0.0	0.0	0.0	Int Door	0	-32.2	514	-9.0
Total	7.0	84.4	0	0.0	ExFr	0	429	47.1	68.0
					Roof	0	0	0	0.0
					Wall	2,311	0	0	0.0
					Ext Door	54	0	0	0.0
					Total	-124.9			

L2 S201

System Checksums

By ACADEMIC

Fan Coil

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES							
Peak'd at Time: Outside Air: OADB/MBHR: 81 / 73 / 112					Mo/Hr: Sum of Peaks OADB: 9					Mo/Hr: Heating Design OADB: -9												
Sens + Lat	Space	Plenum	Net	Percent	Sens + Lat	Space	Plenum	Net	Percent	Sens + Lat	Space	Plenum	Net	Percent	SAOB	Cooling	Heating					
BuIn	BuIn	BuIn	Total	Of Total (%)	BuIn	BuIn	BuIn	Total	Of Total (%)	BuIn	BuIn	BuIn	Total	Of Total (%)	Return	75.2	69.7					
Envelope Loads	0	0	0	0	Envelope Loads	0	0	0	0	Envelope Loads	0	0	0	0	75.2	69.7						
Sky/Solar	0	0	0	0	Sky/Solar	0	0	0	0	Sky/Solar	0	0	0	0	75.2	69.7						
Road Cond	0	0	0	0	Road Cond	0	0	0	0	Road Cond	0	0	0	0	75.2	69.2						
Glass Solar	10.714	0	10.714	56	Glass Solar	10.714	72	10.714	30.89	Glass Solar	-5.746	0	-5.746	7.02	75.2	69.2						
Glass/Door Cond	1.629	0	1.629	8	Glass/Door Cond	-5.746	0	-5.746	30.89	Glass/Door Cond	-1.306	0	-1.306	0.00	75.2	69.2						
Wall Cond	457	0	457	3	Wall Cond	-923	0	-923	0.00	Wall Cond	0	0	0	0.00	75.2	69.2						
Partition/Door	0	0	0	0	Partition/Door	0	0	0	0.00	Partition/Door	0	0	0	0.00	75.2	69.2						
Floor	0	0	0	0	Floor	0	0	0	0.00	Floor	0	0	0	0.00	75.2	69.2						
Adjacent Floor	0	0	0	0	Adjacent Floor	0	0	0	0.00	Adjacent Floor	0	0	0	0.00	75.2	69.2						
Infiltration	1.334	0	1.334	7	Infiltration	-3.309	0	-3.309	17.79	Infiltration	-3.309	0	-3.309	17.79	75.2	69.2						
Sub Total ==>	14.134	190	14.324	75	Sub Total ==>	-9.978	55.70	-10.362	55.70	Sub Total ==>	-10.362	55.70	-10.362	55.70	75.2	69.2						
Internal Loads					Internal Loads					Internal Loads					AIRFLOWS							
Lights	176	44	220	1	Lights	34	0	34	-0.23	Lights	42	0	42	-0.23	Diffuser	840	840					
People	1.663	0	1.663	9	People	0	0.00	0	0.00	People	0	0.00	0	0.00	Terminal	840	840					
Misc	0	0	0	0	Misc	0	0.00	0	0.00	Misc	0	0.00	0	0.00	Main Fan	840	840					
Sub Total ==>	1,640	44	1,684	10	Sub Total ==>	42	0.00	42	-0.23	Sub Total ==>	-9.978	55.70	-10.362	55.70	Sec Fan	0	0					
Ceiling Load	53	-53	0	0	Ceiling Load	-79	0	-79	0.00	Ceiling Load	0	0.00	0	0.00	AHU Vent	94	94					
Ventilation Load	0	0	0	0	Ventilation Load	0	0.00	0	0.00	Ventilation Load	0	0.00	0	0.00	Min Vent	94	94					
Aq Air Trans Heat	0	0	0	0	Aq Air Trans Heat	0	0.00	0	0.00	Aq Air Trans Heat	0	0.00	0	0.00	MultiStop/Rh	94	94					
Dehumid Ov Sizing	0	0	0	0	Dehumid Ov Sizing	-41	0	-41	0.22	Dehumid Ov Sizing	-41	0	-41	0.22	Return	825	825					
Exhaust Heat	-19	-19	0	0	Exhaust Heat	0	0.00	0	0.00	Exhaust Heat	0	0.00	0	0.00	Rm Exh	53	53					
Sup Fan Heat	531	531	0	0	Sup Fan Heat	-7,748	41.65	-7,748	41.65	Sup Fan Heat	0	0.00	0	0.00	Auxiliary	0	0					
Reet Fan Heat	0	0	0	0	Reet Fan Heat	0	0.00	0	0.00	Reet Fan Heat	0	0.00	0	0.00	Leakage Dwn	0	0					
Duct Heat Pump	0	0	0	0	Duct Heat Pump	0	0.00	0	0.00	Duct Heat Pump	0	0.00	0	0.00	Leakage Ups	0	0					
Underfrt Sup Ht Pump	0	0	0	0	Underfrt Sup Ht Pump	0	0.00	0	0.00	Underfrt Sup Ht Pump	0	0.00	0	0.00								
Supply Air Leakage	0	0	0	0	Supply Air Leakage	0	0.00	0	0.00	Supply Air Leakage	0	0.00	0	0.00								
Grand Total ==>	16,027	162	19,223	100.00	Grand Total ==>	-10.064	-18.604	100.00		Grand Total ==>	-10.064	-18.604	100.00									
															ENGINEERING CKS							
															Cooling					Heating		
															% OA					11.2	11.2	
															chmFt					1.09	1.09	
															chmFt					488.93	488.93	
															fr/tion					448.30	448.30	
															BuInHt-Ft					26.77	26.77	
															No. People					8	-24.15	

Project Name: DP&L Building
Dataset Name: DP&L_v11.trc
TRACES® 700 v6.2.8 calculated at 06:15 PM on 04/01/2013
Alternative - 1 System Checksums Report Page 56 of 105

COOLING COIL SELECTION					HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/MBHR	Leave DB/MBHR	Gross Total	Glass	Main Htg	Aux Htg	Humidtr
ton	MBH	cfm	F	F	ft ²	(%)	MBH	cfm	gr/s
Main Ctg	1.6	19.2	15.2	75.5	770	0	-10.9	840	69.2
Aux Ctg	0.0	0.0	0.0	0.0	Part	0	0.0	0	0.0
Opt Vent	0.1	1.4	1.1	94	Int Door	0	0	0	0.0
Total	1.7	20.6	0	0.0	ExFr	0	0	0	0.0
					Roof	0	0	0	0.0
					Wall	344	149	94	-9.0
					Ext Door	0	0	0	65.0
					Total	-18.6			

NOTE: THESE TWO CHECKSUM SHEETS (FLOOR 1 ROOM 104 SOUTH & FLOOR 2 SUITE 201) ARE REPRESENTATIVE SAMPLE DATA TO SHOWCASE THE TWO SYSTEMS

ASHRAE

University of British Columbia
Student Union

TRANE CHECKSUM

DRAWING NO. MI-001

REV 0

REV 0

ISSUED TO ASHRAE COMPETITION

REVISION

UBC ASHRAE TEAM

DRAWN BY DATE

13/04/26

CHECKED BY DATE

PRODUCED BY AN AUTODESK EDUCATION PRODUCT